

Pre-Application Checklist: Copy of Contract \_\_\_\_ Insurance Certificates \_\_\_\_

## Nether Providence Generator Permit Application

214 Sykes Lane Wallingford, PA 19086

610-566-4516

Site Address \_\_\_\_\_ City \_\_\_\_\_

Type \_\_\_\_\_ Property Owner \_\_\_\_\_

Primary Contact \_\_\_\_\_ Phone \_\_\_\_\_ Email \_\_\_\_\_

Contractor \_\_\_\_\_ Address \_\_\_\_\_

Primary Contact \_\_\_\_\_ Phone \_\_\_\_\_ Email \_\_\_\_\_

What is the service gas pressure at this location \_\_\_\_\_ What size pipe will be used for the main gas run \_\_\_\_\_

What type of pipe will be used \_\_\_\_\_

What is the total developed length of the gas line for the generator \_\_\_\_\_

What type of transfer switch will be used \_\_\_\_\_ Will load shedding be provided \_\_\_\_\_

### Installation Checklist

5' clearance to operable openings 10' to mechanical air intakes

Manufacturer's clearances met. Typically 36" min. a side, but back can be 18"

Non-combustible base provided

Gas line enters/exits structure above grade

Galvanized lines are not approved for direct burial

Poly gas lines must be 18" below grade with a sand base and tracer wire

Gas shut off at unit, and flexible connector with no bends provided

Electrical load evaluated and generator sized by a qualified professional

Gas line sized by a qualified professional, and service capacity approved by utility

Description of Work \_\_\_\_\_

Applicant Signature \_\_\_\_\_ Date \_\_\_\_\_

Cost of Job Mechanical \_\_\_\_\_ Cost of Job Electrical \_\_\_\_\_

Municipal Comments:

Mech. Permit Fee \_\_\_\_\_ +\$4.50 Elec. Permit Dee \_\_\_\_\_ +4.50 Total Fee \_\_\_\_\_

3<sup>rd</sup> Party Signature \_\_\_\_\_ Date \_\_\_\_\_

All mechanical inspection requests or code questions should be directed to Linn Architects at [permits@rlinn.com](mailto:permits@rlinn.com) or 610-566-7044 option 2. For the electrical inspection portion, call Dave at United Inspection Agency: 484-443-8895.